



6390 Phillips Highway
Jacksonville, FL 32216
Phone (904) 737-7144

SPECIFICATION DATA SHEET

MODEL No. 2001

SLOT DIFFUSER PLENUM

Date: 03/19/02 rev. Drawn by: M.D.C.

DIMENSIONAL DATA

LENGTH: AS REQUIRED
MAXIMUM 72" PER SECTION
HEIGHT: 10" STANDARD
(OTHER UPON REQUEST)
"X" DIMENSION: AS REQUIRED
"Y" DIMENSION:
"X" PLUS 2" WITH R-4 INTERNAL INSULATION
"X" PLUS 3" WITH R-6 INTERNAL INSULATION
COLLAR: 2" LONG

FABRICATION DATA

MATERIAL:
HOT DIPPED GALVANIZED STEEL SHEET
PER ASTM-A653 CS TYPE B.
26 GAUGE STANDARD.

FEATURES

END TREATMENTS VARY WITH DIFFUSER
ATTACHMENT REQUIREMENTS.
COLLAR SIZES 4" THRU 9" DIAMETER TO BE
ROUND.
COLLAR SIZES 10" DIAMETER AND GREATER
TO BE OVAL.
1" THICK R-4 INTERNAL INSULATION STANDARD.

OPTIONS

TOP ENTRY COLLAR (SIDE ENTRY COLLAR
SHOWN)
NO INTERNAL INSULATION.
1/2" THICK INTERNAL INSULATION.
1-1/2" THICK R-6 INTERNAL INSULATION.

SPECIAL NOTES

X= "D" on Reliable submittal
which is the Duct Opening Width

