

EXTRUDED ALUMINUM LOUVER

MODEL 4-DLF DRAINABLE 33°

SPECIFICATIONS

FRAME
 .081 THICK EXTRUDED ALUMINUM
 6063-T5 MILL FINISH

BLADE
 .081 THICK EXTRUDED ALUMINUM
 6063-T5 MILL FINISH

BLADE SPACING
 APPROX 3-1/4" CENTERS EXCEPT AT HEAD AND SILLS
 CORROSION RESISTANT STEEL FASTENERS USED AT ASSEMBLY

MINIMUM HEIGHT
 8"

MAXIMUM SINGLE SECTION
 240" W X 240" H

SCREEN
 BIRD SCREEN 1/2" X 1/2" ALUMINUM

FLANGE
 1-1/2"

OPTIONAL SCREEN:
 INSECT SCREEN 18 X 16 MESH ALUMINUM

OPTIONAL FINISHES:
 CLEAR ANODIZE
 ANODIZE COLORS
 PAINT
 KYNAR

PLEASE SPECIFY
 SCREEN INSIDE OUTSIDE
 FINISH _____
 MISC. _____

DRAINABLE LOUVERS:
 Water is carried off by an integral gutter in the blade which is channeled through an integral downspout in the jamb, the water is then routed back onto the louver sill and out the front of the louver which, in most conditions, eliminates the need for a subsill or flashing.

LOUVERS WILL BE SUPPLIED AS ORDER WIDTH -1/4" X ORDER HEIGHT -1/4" UNLESS SPECIFIED 'ACTUAL SIZE'

| MARK | QUAN. | WIDTH | HEIGHT | JOB NAME: |
|------|-------|-------|--------|-----------|
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |
| | | | | |


LOCATION: _____

ARCHITECT: _____

ENGINEER: _____

CONTRACTOR: _____

10544-REV-A-2



LLOYD INDUSTRIES INC.

231 COMMERCE DRIVE
 MONTGOMERYVILLE, PA. 18936
 TEL: 215-412-4445
 FAX: 215-412-4409
 EMAIL: LLOYDIND@FIREDAMPER.COM

5858 BROADWAY AVE.
 JACKSONVILLE, FL. 32254
 TEL: 904-378-8440
 FAX: 904-378-8441
 EMAIL: LLOYDINDI@BELLSOUTH.NET

WEB SITE: FIREDAMPER.COM